ARIZONA DEPARTMENT OF WEIGHTS AND MEASURES
1688 W. Adams St., Phoenix, AZ 85007
Phone: 602-771-4920 or 1-800-277-6675 (Outside of Phoenix Metro)
Agency contact: Shawn Marquez (602) 771-4929 www.azdwm.gov
State Ombudsman 602-277-7292

V/R Daily Inspection Log

Must Be Kept Under Penalty of Law R20-2-909

Balance Systems

Month: _____ **Year:** _____

	DISPENSERS	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
1	Nozzle Instruction & Oxygenate Decals posted & readable?																																1
2	Weights & Measures number posted / readable? (602) 2555211																																2
3	Open Dispensers: Check for any leaks or drips.																																3
4	Are all lights lit & all displays readable?																																4
	NOZZLES																																
1	Are any Bellows torn, cut, ripped?																																1
2	Are any Bellows loosened from the nozzle?																																2
3	Is the faceplate smooth, not torn, forming a tight seal?																																3
4	Is the Nozzle dripping gasoline?																																4
5	Have the hoses been drained of residual gasoline DAILY?																																5
6	Does the Trigger work properly? Moves freely when Boot NOT depressed & no fuel can be dispensed?																																6
7	Does the hold open latch work? Properly? 8. Does the auto shut-off work properly?																																7
	HOSES																																
1	Are any hoses cut- crimped- torn flattened- frayed or dragging on the ground?																																1
2	Are the hoses loops 10 inches maximum?																																2
3	Is the breakaway on the nozzle side of the reactor connection? Is any fuel leaking from the connections?																																3
4	Are all of the retractors working properly?																																4
	SWIVELS																																
1	Do all swivels move freely? No signs of binding or leaking?																																1
	UNDERGROUND STORAGE TANKS																																
1	Are spill buckets CLEAN & DRY?																																1
2	Are the caps locked on securely? With gaskets in place?																																2
3	With the caps on, can you turn the pipes?																																3
4	Is the fill tube in good condition?																																4
5	Are there any dents/ cracks in the fill tube?																																5
6	Are the fills labeled correctly by Grade and Oxygenate Type?																																6
7	Are PV valves on the vent pipes? Are they damaged?																																7
	PERMITS																																
1	Are Permits and licenses posted/ readily available to Regulators?																																1
2	**Are Inspection & Maintenance logs CURRENT, COMPLETE & CORRECT?**																																2
3	Are originals/copies of the last 4 gas drops available to Regulators?																																3

If you are having any problems with the above, immediately tag the equipment 'OUT of ORDER'.

Fill out the Owner Operator Repair/ Maintenance Log and contact Maintenance for repairs. The equipment must be tested by a licensed RSR in order to put the equipment back into service. According to A.A.C. R20-2-602 (B)(1)(c).

Owner Operator _____ **Date** _____

I certify this to be accurate and complete as required under A.A.C. R20-2-907 and R20-2-909 and I acknowledge that not maintaining or falsification of this document is a violation of this chapter and subject to civil penalties under A.R.S. 41-2115.