



Arizona Department of Weights and Measures
Vapor Recovery Alert No. 12

Use of the OPW EVR 61SO Overfill Protection in Vaulted Systems

September 26, 2005

The Department of Weights and Measures is issuing this *Vapor Recovery Alert* to inform the Registered Service Agency (RSA) community that the Department has determined that the OPW 61SO-EVR can be used in vaulted systems only. The Department has determined that OPW has addressed to the satisfaction of the Department the concerns the Department had with the OPW 61SO; this new equipment can therefore be use for overfill protection in vaulted systems. This approval for the use of this equipment is limited to vaulted systems only and is effective as of the date of this Vapor Alert. This approval is also conditional upon the proper installation of the equipment by a certified OPW installer. Any equipment not meeting these conditions will be tagged out of service until such time as the Department can ensure the system integrity.