



## Arizona Department of Weights and Measures *Vapor Recovery Alert No. 13*

### Required Testing of Hanging Hardware

**November 29, 2005**

---

The Department of Weights and Measures is issuing this *Vapor Recovery Alert* to inform the Registered Service Agency (RSA) community and our stakeholders about a modification to its requirement regarding testing after making a repair or replacing a vapor recovery system or component.

When an RSR repairs or replaces the hanging hardware, (i.e. hoses, nozzles, or breakaways), the required testing called for under Vapor Alert No. 5 will no longer be required.

This change in testing requirements only applies to hanging hardware. You will be required to test all other modifications that require you to break into the system once the repair or replacement is completed.

This change applies to the owner operator and the RSA/RSR community. It takes effect on the date of this *Vapor Alert*.

This determination does not alter any other requirements, including reporting, permit requirements, or any other testing requirements. Included with this *Vapor Alert* is a copy of a letter sent to the Western States Petroleum Association (WSPA) regarding this issue and some other issues as well. A copy of *Vapor Alert No. 5* is also included. The letter to WSPA can also be found on the vapor recovery RSR web page:

[www.azdwm.gov/business/VR%20RSR.htm](http://www.azdwm.gov/business/VR%20RSR.htm)

This *Vapor Alert* Modifies, but does not eliminate, the requirements previously outlined in *Vapor Alert No. 5*.