



Arizona Department of Weights and Measures *Vapor Recovery Alert No. 9*

Requirement to conduct Pressure Decay Test

August 30, 2005

The Department of Weights and Measures is issuing this *Vapor Recovery Alert* to inform the Registered Service Agency (RSA) community that the Department is requiring that both TP 201.5 and TP 201.4 must be conducted to determine the vapor recovery system integrity when replacing a fuel dispenser at a service station that is equipped with Stage I and Stage II vapor recovery. This requirement applies to the replacement of one or more dispensers at a location. The repair and replacement testing verification form must be included with the place-in-service report when submitted to the Department. This requirement is effective as of the date of this alert.